# **Technical Specification - GreaseShield®1000 AST**





# GreaseShield® The Grease Management Solution

## **APPLICATIONS**

- Prep Sinks
- Small Pot Wash Sinks

## FLOW RATES & CERTIFICATION

- Pro-Active Flow Rate 1 L/sec
- ASME Certification
- **PDI** Certification
- CSA Certification
- EN 1825 Certification

## **STANDARD FEATURES & FUNCTIONS**

- Automatic FOG & solids removal
- Self cleaning
- Magnetic baffle for bioremediation
- PLC controlled
- Reverse flow configuration
- Space Saver Running Trap & Sampling Point
- Globally certified award winning technology

Environmental Products and Services Ltd Award Winning Technology

#### Plumbing Connections

Inlet	1"1/4/3
Outlet	2"/5
Hot Water Solenoid	3/4"/

34mm 0mm 22m

Electrical Ratings	USA	UK,EU,AU,NZ
Voltage	120v	230v
Frequency	60Hz	50Hz
Current	1.5A	0.75A

#### **Standard Operational Times**

Days of Operation 7 Days a Week Hours of Operation 07:00-02:30 Note: Operational times should be adjusted to suit the needs of the kitchen

**Average Power Consumption** 39.1W Per Hour

## **CERTIFICATIONS & APPROVALS**

- PDI G101 (Plumbing & Drainage Institute)
- ASME A112.14.3 & A112.14.4 (American Society of Mechanical Engineers)
- NSF International (National Sanitation Foundation)
- CSA (Canadian Standards Association) Grease Interceptors
- UL (Underwriters Laboratory)
- IAPMO (International Association of Plumbing and Mechanical Officials) Uniform Plumbing Code Certification Mark
- UKCA (UK Conformity Assessed)
- CE Conformity with Health, Safety and Environmental Protection \ Standards with the European Economic Area (EEA)
- EN1825 (European Standard for Grease Separators)
- KIWA (ETA DK, Swedac & SINTEF) Sweden, Norway and Finland. European Institution for Testing, Inspection and Certification
- SHASE-S 217:2016 (Japanese Grease Management Standard for Grease Interceptors)

#### V10 09/09/2024

www.GreaseShield.com HEAD OFFICE +44 (0) 28 3083 3081

sales@epas-ltd.com

GB OFFICE +44 (0) 161 477 5555

## Technical Specification - GreaseShield®1000 AST

